



Product Service

CERTIFICATE

No. Z2 115953 0002 Rev. 00

Holder of Certificate: **More Energy GmbH**

Fürther Str.38
90429 Nürnberg
GERMANY

Certification Mark:



Product:

Crystalline Silicon Terrestrial Photovoltaic (PV) Modules
Mono-Crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 701262202502-00

Valid until: 2026-10-10

Date, 2022-02-23

(Zhulin Zhang)



Product Service

CERTIFICATE

No. Z2 115953 0002 Rev. 00

Model(s):

MExxxG12-110GA (xxx=525-550 in step of 5W)
MExxxM10-144GA (xxx=530-550 in step of 5W)
MExxxM10-132GA (xxx=485-500 in step of 5W)
MExxxM10-120GA (xxx=445-455 in step of 5W)
MExxxM10-108GA (xxx=400-410 in step of 5W)
MExxxM6-144GA (xxx=430-455 in step of 5W)
MExxxM6-132GA (xxx=395-415 in step of 5W)
MExxxM6-120GA (xxx=360-380 in step of 5W)
xxx is standing for rated output power at STC

Parameters:

Safety Class:	Class II
Max. System Voltage:	1500V DC
Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute No. 10 West Kaifa Road, Yangzhou 225009 Jiangsu, P. R. China
Construction:	Framed, with Junction box, cable and connector.
Fire Safety Class:	Class C according to UL790

Tested according to:

IEC 61215-1:2021
IEC 61215-1-1:2021
IEC 61215-2:2021
IEC 61730-1:2016
IEC 61730-2:2016